

UNITED STATES GOVERNMENT

Memorandum

25X1A5a1

TO : The Files: [REDACTED]

DATE: 7 March 1963

FROM : [REDACTED]

25X1A9a

SUBJECT: Trip Report - MAX-1 with [REDACTED]

25X1A5a1

25X1A

1. Project Description:

MAX-1 is a fully automatic, electronic, solid-state stored program store and forward message switching system. The system is to replace an existing teletype torn tape relay station and shall route traffic in accordance with ACP-127.

2. Contractual Information:

- a. Initial Cost: [REDACTED]
- b. Initiation Date: 1 March 1963
- c. Completion Date: 1 March 1964
- d. Deliverable Items: MAX-1 Switch

25X1A5a1

3. Date of Meeting: 1 March 1963

25X1A5a1

4. Place of Meeting: [REDACTED]

5. Persons Attending:

Agency

Non-Agency

25X1A9a

Mr. [REDACTED]
Mr. [REDACTED]
Mr. [REDACTED]
Mr. [REDACTED]

Mr. [REDACTED]
Mr. [REDACTED]
Mr. [REDACTED]
Mr. [REDACTED]
Mr. [REDACTED]

25X1A5a1

6. Contractor's Performance:


- a. On Schedule and expected to remain so: Yes
- b. Within Obligated Funds and expected to remain so: Yes
- c. Satisfactory Technical Progress: Yes

7. Project Status:

25X1A5a1

[REDACTED] presented their tentative floor plan (see attached) showing the disk files enclosed within a glass-walled area

~~SECRET~~



25X1A

SUBJECT: Trip Report - MAX-1 with [REDACTED]

25X1A5a1

in the shield area. This plan developed from the "NO SMOKING" requirement for the disk file but not for the rest of the equipment. This drawing was approved for the continuation of planning with the exception that the M. G. units shown in the air conditioning room will probably be moved to the power building.

25X1A5a1

[REDACTED] also gave us Environment and Floor Loading specifications for the disk file. (see attached)

25X1A5a1

A plant inspection was made and we were shown computers in various stages of construction. We also saw the [REDACTED] computer, 25X1A5a1 from a distance, switching [REDACTED] messages.

It has definitely been decided by [REDACTED] not to do the shield room part of the project. 25X1A5a1

25X1A9a

Attachments:

- (1) Floor Plan
- (2) Environment and Floor Loading Specifications

Distribution:

R&D Subject File
Inspection Branch/OL/PD
R&D Lab
OC-OS
ESB
Monthly (2)
EP Chrono

a wise decision on their part

MISSING PAGE

ORIGINAL DOCUMENT MISSING PAGE(S):

No Att